

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No: 7120-0553:102

Page 1 of 1

CATEGORY: Annunciators

LISTE: Space Age Electronics, 406 Lincoln Street, Marlborough MA 01752
Contact: *Patricia Belhumeur (508) 485-0966

DESIGN: Model XL8 and GL8 annunciators, followed by -BL, -RM; followed by -B, -L, -R, -T, -W, -X, -Y, -Z; followed by -A, -B, -C, -D, -F, -H, -J, -Z; followed by -F, -R, -S, -X; followed by -B, -R, -Z; followed by -F1, -R1, -W1, -FD, -RD, -WD, -A1, -C1, -LD, -P1, -MD, -S1; followed by 02 or 24; followed by -A, -D; followed by -1, -2; followed by SLT, PLT, PHM, PLO, PHT, PHR, PCC, PWT, PWK, O, K, T, T; followed by 1, 2; followed by number of zones. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 12/24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number and UL label.

APPROVAL: Listed remote annunciators for use with separately listed compatible fire alarm control units.

*Rev. 07-17-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 11, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND**, Senior Deputy
Program Manager